



Pressure Test Certification Affidavit

In accordance with the Florida Building Code (FBC) 2014 (5th Edition) Sections R4501.12.1 and FBC 454.2.12.1 all pool piping shall be tested and proved tight to the satisfaction of the administrative authority, under static or air pressure test, of not less than, thirty-five (35) P.S.I. for fifteen (15) minutes. This affidavit is to satisfy the pool piping has been tested and the piping has been verified as tight. Exemption: Circulating pumps need not be tested as required in this section.

Test Data Required:

Start Date: _____ Start Time: _____

Beginning Pressure: _____

End Date: _____ End Time: _____

Company Name: _____

Telephone: _____

Permit Number: _____

License Holder: _____

I, _____, the license holder/owner builder in charge of supervising the code compliant construction of this permitted pool construction located in the Village of Estero, hereby certify and accept responsibility that the pool piping for this project has tested and proved tight.

License Holder/Owner Builder Signature: _____

Date: _____